

CUMBERLAND COUNTY UTILITIES AUTHORITY
BRIDGETON, NJ
ADDENDUM NO. 1

For

CLEANING & REMOVAL OF CONTENTS OF PRIMARY DIGESTER AND STORAGE TANK

TO ALL CONCERNED:

Bidders of the above captioned project are hereby notified of the following amendments to the Specifications for the following bid opening on February 14, 2019, which are hereby made a part of the Contract Documents.

Concerning General Information for Tanks:

1. Site visits are to be coordinated with Bob Carlson through email bcarlson@ccua.info or by phone (856) 455-7120 ext. 129.
2. All (3) tanks will **not** be available at the same time for specified work.

Concerning the Specifications:

1. **PART 1 GENERAL INFORMATION, SECTION 1.01 SCOPE OF WORK**
 - Paragraph A, Item # 2: Bidding Contractor is solely responsible for transportation costs and the CCUA is responsible for (Tipping) fees of the screenings.
 - Paragraph B:
 - Pipeline Cleaning – Bidding Contractor responsible to dispose of material associated with the pipeline cleaning in a legal manner.
 - Sludge Lines – There are (2) two known 90-degree Elbows in the Sludge Lines to be videoed and cleaned, Owner (CCUA) makes no representation to the total number of 90-degree Elbows. (See drawings on the CCUA website under the current projects tab.)
2. **PART 2 – EXECUTION, SECTION 2.01 GENERAL**
 - Paragraph A: Regarding Manways – Please see drawings on the CCUA website under the current projects tab, Bidding Contractor to field verify.
3. **PART 1 GENERAL INFORMATION, SECTION 2.02 REMOVAL OF DIGESTER CONTENTS**
 - Paragraph A: Regarding Dewatered material – If Dewatered Material does not reach 20%, it is the bidding contractor's responsibility to dispose of the material in a legal manner.
 - Paragraph A: Regarding Roll off Boxes supplied by the Owner (CCUA - The owner will supply only (3) Three Roll off Boxes maximum.
 - Paragraph E: The Dewatered Sludge must be disposed of offsite, screened wastewater may be returned to the in-use digester or on-site storage tank if storage is available. This must be arranged through the CCUA.
 - Paragraph F: The owner's initial inspection will NOT determine if additional inspection is necessary.

The entire Addendum No. 1 can be viewed and available on the Cumberland County Utilities Authority website www.ccua.info or may be attained by contacting CCUA at 856-455-7120.